


# Atmosphere Monitoring at BEO Moussala



**Peter Ivanov**

Basic Environmental Observatory Moussala  
Institute for Nuclear Research and Nuclear Energy  
Bulgarian Academy of Sciences

# Actual status of atmosphere monitoring at BEO Moussala in real time

## *1. Gas concentration measurements*

*1.1. Carbon monoxide*

*1.2. Sulfur dioxide*

*1.3. Nitrogen monoxide*

*1.4. Nitrogen dioxide*

*1.5. Ozone*

*1.6. Carbon dioxide*

## *2. Aerosol measurements*

*2.1. Optical properties –  
Light scattering  
coefficient*

*2.2. Physical properties –  
Particle size distribution*

# Automatic System for Gas Concentration Measurements Environment at BEO



NO and NO<sub>2</sub> analyzer AC32M  
Method: Chemiluminescence  
Sensitivity: 0.4 ppb








CO analyzer CO12M, Method: NDIR  
Sensitivity: 0.05 ppm

SO<sub>2</sub> analyzer AF22M, Method: UV-fluorescence, Sensitivity: 1 ppb

O<sub>3</sub> analyzer O342M  
Method: UV-Photometry  
Sensitivity: 0.4 ppb

# Data Acquisition Software and Data Access

Measured data is stored into Ms SQL database at local PC. There are records for average concentrations and status of each analyzer at every 1, 15 and 60 min. At every 15 min. the data is imported into the main My SQL data base and is available via internet as a plot on the web page. The access to detail row data is available by some data base client as Navicat - access authorization by username and password is required.





# Remote access and remote calibration possibilities

The sophisticated software gives flexible possibilities for remote access to the acquisition PC. Each analyzer has an intelligent communication interface and is accessible for remote control checks, diagnostics and calibrations. The remote operator can log in directly to each of analyzers via Internet, to browse through the menus to check zero drift, calibration drift or test control signals; to start reference zeroing, calibration cycle or whatever it is necessary.

The screenshot displays a Windows XP desktop environment. On the left, a 'Profile: RemoteEnvidas.tlp' window is open, showing a 'Login' tab with fields for 'Server' (195.96.232.117:3001), 'Username' (moussila), and 'Password'. A 'User Authentication' dialog box is also visible, showing a failed login attempt with the message: 'Authentication failed. Remaining authentication methods: password,publickey,gsasl with mdc.'.

In the center, the 'Envidas for Windows - inrne' application is running, displaying a 'Dynamic Tabular' window. This window shows a table of data for various channels (01-06) and a graph of the input signal. The graph shows a signal fluctuating around 0.4, with a peak at 0.446d. The graph also displays temperature (33°C) and pressure (0.180mb).



On the right, a 'Serveur de communic...' window is open, showing a 'Principal' tab with a 'READY' status. Below this, a 'Digital Input' and 'Digital Output' table is visible.

The taskbar at the bottom shows several open applications, including 'Start', 'Envidas for Windows - inrne', 'COMADRESSES.txt - N...', 'Server Comm', and 'Contact for Windows - D...'. The system clock shows the date 09/03/07 and time 21:03.

# Some results of CO measurements




The average concentration of CO for last six months is about of 0.14 ppm. The maximum is in February 2007 – 0.18 ppm.

There are several days (3, 6, 7, 19, 22 of February) with concentrations higher than average for the month. The direction of the wind on 3 has been from E-NE – direction of the largest thermo-electricity power plant in Bulgaria “Maritza-Iztok”. On 6, 7 and 22 February there has been a strong wind from W-NW with velocity of about 15-20 m/s. That wind has been transporting polluted air from thermo-electricity power plant “Bobovdol”.



# Some results of SO<sub>2</sub> measurements



The average concentration of SO<sub>2</sub> for last six months is about of 1.07 ppb. There are peaks in November 2006 (3.10 ppb), February 2007 (1.50 ppb) and March 2007 (2.05 ppb). There is only one day November 21 with extremely higher concentrations than average for the month—21.90 ppb. The direction of the wind on 21 has been mainly from N-NW. There has been several days in February 2007 with extremely higher concentrations than average for the month—16 (13.66 ppb), 17 (3.91 ppb) and 22 (7.72 ppb). The direction of the wind on 16 and 17 has been mainly from E-NE. This is the direction of the largest thermo-electricity power plant “Maritza-Iztok” in Bulgaria. The wind on 22 has been transporting polluted air from W-NW - direction of another thermo-electricity power plant “Bobovdol”.



# Some results of NO measurements

The average concentration of NO for last six months is about of 0.76 ppb. The maximums of measured concentrations are in February and March 2007 – 2.12 ppb and 2.34 ppb.




There are some days (16, 17, 22 of February) with concentrations higher than average for the month – 11.15 ppb, 7.26 ppb and 22.85 ppb respectively. The direction of the wind on 16 and 17 has been mainly from E-NE. This is the direction of the largest thermo-electricity power plant “Maritza-Iztok” in Bulgaria. On 22 the wind has been blowing from W-NW mainly – direction of another one thermo-electricity power plant “Bobovdol”








# Some results of NO<sub>2</sub> measurements






The average concentration of NO<sub>2</sub> for last six months is about of 5.11 ppb. There are peaks in January (11.56 ppb), February (9.93 ppb) and March 2007 (17.28 ppb). In January there are several days with high concentrations – 3 (38.72 ppb), 6 (21.24 ppb), 7 (20.17 ppb), 20 (24.27 ppb), 26 (22.12 ppb), 28 (34.80 ppb), 29 (29.25 ppb), 30 (33.76 ppb), 31 (39.93 ppb); in February – 2 (23.51 ppb), 4 (22.93 ppb), 16 (34.77 ppb), 17 (31.01 ppb), 18 (35.38 ppb); in March – 2 (24.26 ppb), 4 (22.28 ppb), 5 (19.43 ppb). The direction of the wind on 3, 6, 20, 28, 29, 30 and 31 January has been from E-NE. On 26 January has been from W-NW. On 2, 4, 16, 17, 18 February the wind has been blowing from E-NE.





# Some results of O3 measurements

The average concentration for last six months is about of 42.12 ppb. The highest concentration has been in September 49.92 ppb. The minimum has been in January – 34.36 ppb. In February and March the average concentrations have been also lowest than average. For this months the concentrations of NO and NO2 have had maximums.









# Summary of Gas Concentration Measurements

- There has been several extremely high peaks for measured concentrations of CO, SO<sub>2</sub>, NO and NO<sub>2</sub> on 16, 17 and 22 of February.
- The wind direction on those days has been mainly from regions with thermo-electricity power plants – the largest in Bulgaria “Maritza-Iztok” and “Bobovdol”.
- The average monthly concentrations for SO<sub>2</sub>, NO and NO<sub>2</sub> increase after January 2007 – the day of stopping of 3 and 4 reactors of nuclear power plant “Kozloduy”.

# Measuring of optical parameters of aerosols

Measurements of light scattering coefficient and back-light scattering coefficient of aerosols are provided by TSI Integrating Nephelometer model 3563. TSI Integrating Nephelometer is designed specifically for studies of direct radiative forcing of the Earth's climate by aerosol particles. The light-scattering coefficient is a highly variable aerosol property. Integrating Nephelometer measures the angular integral of light scattering that yields the quantity called the *scattering coefficient*, which is used in the Beer-Lambert Law to calculate total light extinction. Model 3563 includes three-wavelength and back-scatter features – wavelengths 450 nm (blue); 550 nm (green) and 700 nm (red). TSI Integrating Nephelometer has been operating at BEO Moussala since 21-th of February 2007. The creation of the software for data-import from measurements into a database is in progress. The inlet for aerosol measurements is designed to sample total air without any size cuts. It has heating control system to reduce relative humidity of sampled air. The inlet is made by Institute of Tropospheric Research of Leipzig (IFT) according with GAW requirements of WMO.

A screenshot of the TSI Integrating Nephelometer software interface. The window is titled "TSI Integrating Nephelometer" and contains several sections for data display and control. The "Scattering Coefficient" section shows data for Blue, Green, and Red wavelengths. The "Backscatter" section shows data for Back and Backlight. The "Inlet Temp" and "Sample Temp" are displayed. The "Rel Humidity" and "Inlet Pressure" are also shown. The interface includes buttons for "Query", "Stop Data", "Zero", "Exit", and "Help".

| Scattering Coefficient |         |
|------------------------|---------|
| Wavelength             | Value   |
| Blue                   | 6.93e-6 |
| Green                  | 4.97e-6 |
| Red                    | 3.03e-6 |

| Backscatter |         |
|-------------|---------|
| Wavelength  | Value   |
| Back        | 1.16e-6 |
| Backlight   | 1.17e-6 |

Inlet Temp: 284.5 K  
Sample Temp: 1301.3 K  
Rel Humidity: 72 %  
Inlet Pressure: 1043 mbar

# Planned atmosphere monitoring measurements

## Continuous Measurement in real time

Gas concentration measurements of CO<sub>2</sub>

Aerosol size distribution

Concentration of aerosols

## Intermittent Measurement

Detailed size fractionated chemical composition

# ***BEO Moussala contacts:***

**Prof. D.Sc. Jordan Stamenov**  
**e-mail: [jstamen@inrne.bas.bg](mailto:jstamen@inrne.bas.bg)**  
**tel: +359 2 9743761**  
**fax: +359 2 9753619**  
**Mobile: +359 88 8874333**

**Peter Ivanov**  
**e-mail: [petkoiv@inrne.bas.bg](mailto:petkoiv@inrne.bas.bg)**  
**tel/fax: +359 2 9746310**  
**Mobile: +359 88 9218156**

<http://beo-db.inrne.bas.bg>